



New Jersey Department of Health
Environmental and Chemical Laboratory Services
PO Box 361, Trenton, NJ 08625-0361
NJDEP Lab ID#: 11036
EPA Lab ID#: NJ01351

Client Address:
The Kids Palace II LLC
85 Whittlesey Avenue
West Orange NJ, 07052

Report Date: 02/13/2026 09:15
Project: NIDCF Childcare Drinking Water

Client Sample ID: **First Floor Kitchen**
Sample Location:
Field ID No: First Floor Kitchen
Sample Type: First Draw

Lab Number: 26A3001-01
Sampled: 1/27/2026 6:10:00AM
Received: 1/30/2026 11:11:36AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	41.5		0.113	0.500	ug/L	02/09/2026	02/11/2026 16:33	EPA 200.8
Lead	0.177	JR	0.100	1.00	ug/L	02/09/2026	02/11/2026 16:33	EPA 200.8

NJDOH PHEL

Dave Riker, Organic Testing Laboratory Supervisor

Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Classroom B Bathroom**
Sample Location:
Field ID No: Classroom B Bathroom
Sample Type: First Draw


Lab Number: 26A3001-02
Sampled: 1/27/2026 6:10:00AM
Received: 1/30/2026 11:11:36AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	42.4		0.113	0.500	ug/L	02/09/2026	02/11/2026 19:03	EPA 200.8
Lead	1.05		0.100	1.00	ug/L	02/09/2026	02/11/2026 19:03	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Classroom A Bathroom**
Sample Location:
Field ID No: Classroom A Bathroom
Sample Type: First Draw


Lab Number: 26A3001-03
Sampled: 1/27/2026 6:10:00AM
Received: 1/30/2026 11:11:36AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	25.9		0.113	0.500	ug/L	02/09/2026	02/11/2026 12:42	EPA 200.8
Lead	0.250	JR	0.100	1.00	ug/L	02/09/2026	02/11/2026 12:42	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Classroom C Bathroom**
Sample Location:
Field ID No: Classroom C Bathroom
Sample Type: First Draw


Lab Number: 26A3001-04
Sampled: 1/27/2026 6:10:00AM
Received: 1/30/2026 11:11:36AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	55.5		0.113	0.500	ug/L	02/09/2026	02/11/2026 12:46	EPA 200.8
Lead	0.523	JR	0.100	1.00	ug/L	02/09/2026	02/11/2026 12:46	EPA 200.8

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor

Client Sample ID: **Classroom C Kitchen**
Sample Location:
Field ID No: Classroom C Kitchen
Sample Type: First Draw

Lab Number: 26A3001-05
Sampled: 1/27/2026 6:10:00AM
Received: 1/30/2026 11:11:36AM

Analyte	Result	Qualifier	Method Detection Limit	Reporting Limit	Units	Prepared	Analyzed	Method
Metals by EPA 200 Series Methods								
Copper	54.4		0.113	0.500	ug/L	02/09/2026	02/11/2026 12:50	EPA 200.8
Lead	0.437	JR	0.100	1.00	ug/L	02/09/2026	02/11/2026 12:50	EPA 200.8

Notes and definitions:


- J Approximate Value
- JR Approximate value. Result is below the reporting level but greater than the method detection limit.

Case Narrative Section:

NJDOH PHEL



Dave Riker, Organic Testing Laboratory Supervisor



Doug Haltmeier, Inorganic Testing Laboratory Supervisor